GLOBAL

AN OWL COMPANY

From: Safety Health & Environmental Manager
To: Project Manager

Subject: EX- GATES (CG 51) REFRIGERANT RECOVERY & UNITARY SYSTEMS INVENTORY

Ref. (a): NAVSHIPS Tech Manual Chapter 050-3.8.2 and 050-9.6.2

Reference (a) requires refrigerant recovery from Refrigerating Plants and Air Conditioning Systems in accordance with the Clean Air Act Amendment of 1990. The following refrigerant systems are identified aboard ex-Gates and were surveyed on 17 June, 2014. The systems identified below may still contain refrigerants.

Compartment Number	Compartment Name	Type	Oz.	System
01-174-0-L	PASSAGE	R143A	4.25	SCUTTLEBUTT
01-190-0-Q	SONAR # 5	UNK	UNK	A/C UNIT
01-215-0-L	CDR PANTRY	UNK	UNK	REFRIGERATOR
01-260-0-L	PANTRY	R404A	UNK	REFRIGERATOR (2)
01-260-0-L	PANTRY	R401A	3.75	MILK MACHINE
01-260-2-L	PASSAGE	R12	20	SCUTTLEBUTT
02-220-2-L	PASSAGE	R143A	4.25	SCUTTLEBUTT
02-292-0-Q	HELO HANGAR	R143A	4.25	SCUTTLEBUTT
03-188-2-Q	ELECT SHOP # 7	UNK	UNK	A/C UNIT
04-153-2-L	PASSAGE	UNK	UNK	A/C UNIT
05-166-1-C	SLIP RING ASSY	UNK	UNK	A/C UNIT
1-138-1-L	PASSAGE	UNK	UNK	A/C UNIT
1-159-0-Q	TECH LIBRARY	UNK	UNK	A/C UNIT
1-174-0-L	PASSAGE	UNK	UNK	A/C UNIT
1-220-3-L	PASSAGE	R134A	74	SODA MACHINE
1-248-0-L	PASSAGE	UNK	UNK	A/C UNIT
1-260-01-L	PASSAGE	R134A	4	SCUTTLEBUTT
1-260-0-Q	GALLEY	R12	32	CHILL BOX (2)
1-260-1-L	CPO MESS	UNK	6.5	JUICE MACHINE
1-260-1-L	CPO MESS	R404A	3.75	MILK MACHINE
1-260-1-L	CPO MESS	R404A	UNK	REFRIGERATOR

Compartment Number	Compartment Name	Type	Lbs.	System
1-260-1-L	CPO MESS	UNK	UNK	A/C UNITS (2)
1-272-0-Q	CPO SERVING ANNEX	R404A	11	CHILL BOX
1-300-0-L	CREW MESS	R404A	UNK	REFRIGERATOR
1-300-0-L	CREW MESS	UNK	UNK	A/C UNIT
1-300-0-L	CREW MESS	R404A	24	ICE MACHINE
1-300-0-L	CREW MESS	R404A	54	ICE CREAM MACHINE
1-300-1-L	PASSAGE	R134A	72	SODA MACHINE
1-316-2-Q	EXT SERVICE LINE	R134A	6.5	JUICE MACHINE
1-316-2-Q	EXT SERVICE LINE	R404A	54	ICE CREAM MACHINE
1-356-0-L	BERTHING	UNK	UNK	SCUTTLEBUTT
1-382-01-L	PASSAGE	R404A	UNK	REFRIGERATOR
1-382-01-L	PASSAGE	R134A	4.25	SCUTTLEBUTT
2-149-0-L	BERTHING	UNK	UNK	A/C UNIT
2-149-0-L	BERTHING	UNK	UNK	SCUTTLEBUTT
2-220-4-Q	REEFER MACH	UNK	UNK	REFER PLANTS (2)
2-236-0-Q	AEGIS COOLING #1	UNK	UNK	A/C UNIT
2-260-1-Q	SUPPLY OFFICE	UNK	UNK	A/C UNIT
2-284-1-L	PASSAGE	R134A	4.25	SCUTTLEBUTT
2-346-01-L	BERTHING	UNK	UNK	SCUTTLEBUTT
2-346-01-L	BERTHING	UNK	UNK	A/C UNIT
2-387-0-Q	WORKSHOP	UNK	UNK	A/C UNIT
2-426-2-L	PASSAGE	UNK	UNK	SCUTTLEBUTT
2-464-1-Q	FAN RM	UNK	UNK	A/C UNIT
3-127-0-Q	FWD IC RM	UNK	UNK	A/C UNIT
3-138-6-L	PASSAGE	UNK	UNK	A/C UNIT
3-138-6-L	PASSAGE	UNK	UNK	SCUTTLEBUTT
3-260-0-A	STORE ROOM	UNK	UNK	A/C UNIT
3-346-0-L	BERTHING	UNK	UNK	A/C UNIT
3-346-0-L	BERTHING	UNK	UNK	SCUTTLEBUTT
3-382-2-Q	AEGIS COOLING	UNK	UNK	A/C UNITS (2)
3-393-4-Q	400HZ ROOM	UNK	UNK	A/C UNIT2 (2)
3-398-0-E	#2 PUMP ROOM	UNK	UNK	A/C PLANTS 3&4
3-440-2-A	STORE ROOM	R12	8	DEHUMIDIFIER
5-174-0-E	MMR #1	UNK	UNK	SCUTTLEBUTT
5-220-0-E	AUX 1	UNK	UNK	SCUTTLEBUTT
5-220-0-E	AUX 1	UNK	UNK	A/C PLANTS (3)
5-300-0-E	MMR 2	UNK	UNK	SCUTTLEBUTT

1. **Total numbers of items on inventory is: 58**

James A. Sirles, EHS Mgr.